



SCHOOL BOARD OF POLK COUNTY

P.O. BOX 391
BARTOW, FLORIDA 33831

1915 SOUTH FLORAL AVENUE
BARTOW, FLORIDA 33830

Purchasing Department
Fax: 863/534-0802

January 21, 2010

Board Members

BOARD CHAIR
KAY FIELDS
DISTRICT 5

FRANK J. O'REILLY
DISTRICT 1

LORI CUNNINGHAM
DISTRICT 2

HAZEL SELLERS
DISTRICT 3

DICK MULLENAX
DISTRICT 4

MARGARET LOFTON
DISTRICT 6

TIM HARRIS
DISTRICT 7

C. WESLEY BRIDGES II
General Counsel

Administration

GAIL F. MCKINZIE, Ph.D.
Superintendent of Schools

ADDENDUM #01

Page 1 of 5

To: All Vendors
From: Scott Clanton
Director of Purchasing and Warehousing
Subject: Bid Number 045-MHH-0110, Window/Glass
Materials - Term Contract

This addendum is issued to answer questions from potential bidders and reflect changes and clarifications to the specifications for the above bid.

All additions are in brackets ([]), **bold type** and double underlined for easy identification. All deletions are indicated by strikethrough (~~strikethrough~~).

We apologize for any inconvenience this may have caused.

Due to limited time before bid opening we will not be able to accept any additional questions.

NOTE:

Among other things, this addendum reflects changes to the specifications. ALL VENDORS BIDDING MUST SIGN AND RETURN PAGE 1 OF THIS ADDENDUM. PLEASE SIGN AND RETURN THIS ADDENDUM IN ITS ENTIRETY WITH YOUR SEALED BID PACKAGE. If you already submitted a bid please complete this addendum sign and return by the deadline for receipt of sealed bids.

VENDOR NAME

***** _____ *****
PRINT OR TYPE SIGNATURE AND TITLE

***** _____ *****
WRITTEN SIGNATURE

*Polk County Schools-
an equal opportunity
institution for education
and employment*

*The Mission of Polk County Public Schools is to ensure rigorous, relevant learning experiences
that result in high achievement for our students.*

Please note the changes to Section C on page 5 of the Invitation to Bid.

C. F.O.B. DESTINATION: Prices bid for all items shall be F.O.B. Destination and include all shipping charges to ~~all Polk County school locations~~ [In-House Construction Service Center 965 Highway 60 East, Bartow FL 33830].

Please note the changes to BID FORM & SPECIFICATIONS of the Invitation To Bid.

BID FORM & SPECIFICATIONS

LOCATION	DESCRIPTION	PRICE
1. Roosevelt Academy 115 East Street Lake Wales, FL 33853	24 Windows - (Fixed Over Project, Fixed & Project Out <u>[Fixed Over Single Hung, Colonial White Finish]</u>), including all glass, muntins, hardware, screens, mullions, subframes, signed and sealed shop drawings and freight to jobsite. Building 4, Room #s 04-001 through 04-005 As per the terms and conditions of this Invitation to Bid and any issued addendum (if applicable). <u>Furnish and deliver only (installation by PCSB In-House Construction).</u>	\$ _____
2. Union Academy Magnet 1795 East Wabash Street Bartow, FL 33839	89 Windows - (Fixed Over Project, Fixed & Project Out <u>[Single Hung Unequal Sash, Clear Anodized Finish]</u>), including all glass, muntins, hardware, screens, mullions, subframes, signed and sealed shop drawings and freight to jobsite. Building 1, Room #s 01-001 through 01-006 Building 2, Room #s 02-001 through 02-003c Building 3, Room #s 03-001a through 03-005 Building 6, Room # 06-004 As per the terms and conditions of this Invitation to Bid and any issued addendum (if applicable). <u>Furnish and deliver only (installation by PCSB In-House Construction).</u>	\$ _____

BID FORM & SPECIFICATIONS continued

LOCATION	DESCRIPTION	PRICE
<p>3. Lakeland Senior 726 Hollingsworth Road Lakeland, FL 33801</p>	<p>128 Windows (Fixed Over Project, Fixed & Project Out including all glass, muntins, hardware, screens, mullions, subframes, signed and sealed shop drawings and freight to jobsite. Building 2, Room #s 02-001 through 02-008 (1st floor) Building 2, Room #s 02-011 through 02-023 (2nd floor) Building 3, Room #s 03-001 through 03-010 Building 4, Room #s 04-001 through 04-018 As per the terms and conditions of this Invitation to Bid and any issued addendum (if applicable). <u>Furnish and deliver only (installation by PCSB In-House Construction).</u></p>	<p>\$ _____</p>
<p>4. Lake Region Senior 1995 Thunder Road Eagle Lake, FL 33839</p>	<p>9 [56] Windows - (Egress windows), <u>[Swing shall be on the Brick side of each egress window, Bronze Anodized]</u> including all applicable glass, muntins, hardware, mullions, subframes, signed and sealed shop drawings and freight to jobsite. Building 1, Room # 01-119 (1st floor) Building 1, Room #s 01-213, 01-215 and 01-217 (2nd floor) Building 2, Room #s 02-202 and 02-203 (2nd floor) Building 3, Room # 03-108 (1st floor) Building 3, Room # 03-203 (2nd floor) Building 4, Room # 04-104 (1st floor) As per the terms and conditions of this Invitation to Bid and any issued addendum (if applicable). <u>Furnish and deliver only (installation by PCSB In-House Construction).</u></p>	<p>\$ _____</p>

Please note the questions and answers below to questions received from potential bidders.

Question:

1. Who will be responsible for field measurements?

Answer

1. *The awarded bidder(s) will be responsible for field measurements.*

Question:

2. Will any of the windows at the sites listed in the Invitation to Bid require tinted impact resistance glass for EHPA rated buildings?

Answer

2. *None of the buildings listed in Invitation to Bid 045-MHH-0110 are EHPA designated/rated buildings, so tinted impact resistance glass as specified in Section 2.01 E. for EHPA buildings is not required.*

Question:

3. Is a thermal barrier required as noted in section 2.01 D.?

Answer:

3. *Yes please bid as per the specifications listed in the Invitation to Bid.*

Question:

4. How should the windows that are currently covered with Wall Hung A/C units be addressed?

Answer:

4. *The existing windows that were modified for the installation of Wall Hung A/C units will be filled in with block, and lintels to support the Wall Hung A/C units. This will be a four foot section of wall as discussed during the Pre-bid conference. These openings were not included in the original window count listed in the bid form.*

Question:

5. Will all windows be tinted?

Answer:

5. *Yes please bid tinted windows as per section 2.01 E.1.*

Question:

6. What type of windows will be installed at Lakeland Senior?

Answer:

6. *The windows at Lakeland Senior (Line item number 3. in the BID FORM & SPECIFICATIONS) have been removed from this Invitation to Bid pending clarification of the window types. After award of this bid the School Board of Polk County will request quotes from the awarded bidders as per the terms and conditions of the Invitation to Bid.*

Question:

7. Are subframes/receptors required for the windows in this bid?

Answer:

7. Yes, all windows at all sites except for Lake Region Senior will require subframes/receptors as per Section 1.02 C.

Question:

8. It was suggested that the Egress windows at Lake Region Senior consist of new vents without a subframe/receptors to facilitate the installation of the egress windows?

Answer:

8. Yes, provided the windows bid have a Florida product approval number.

Question:

9. What is the window type/configuration at Lake Region Senior?

Answer:

9. Fixed Over Casement with the swing on the brick side of the window.

Question:

10. What is the window type/configuration at Roosevelt Academy?

Answer:

10. The windows over the boy's restroom shall be project out with 6 lights to match existing campus window scheme. With one of the openings to be a 5 ply panel to facilitate installation of the exhaust fan. The windows in the girl's restroom shall obscure glass, Single Hung Colonial. Classroom windows shall be Fixed Over Single Hung Colonial with one window opening to have a 5 ply panel to facilitate installation of the exhaust fans.

Question:

11. What is the window type/configuration at Union Academy Magnet?

Answer:

11. Single Hung Unequal Sash with clear anodized finish.

Question:

12. How should the existing fixed glass above the egress doors at Union Academy Magnet be addressed?

Answer:

12. The existing fixed glass above the egress doors at Union Academy Magnet will remain.